

PANEL CAS												
208/120 VOLT, 3 PHASE, 4 WIRE				FLUSH MOUNTED								
400 AMP M.L.O.												
AIC: 22000 AMPS SYM												
CCT NO	LOAD DESCRIPTION	LOAD V.A.	REMARKS	P	AMP SIZE	Ø	AMP SIZE	P	REMARKS	LOAD V.A.	LOAD DESCRIPTION	CCT NO
1	PROCEDURE	1440		1	20	A	20	1		1800	EXAM	2
3	EXAM LIGHT	1000		1	20	B	20	1		1800	EXAM	4
5	PROCEDURE	1620		1	20	C	20	1			SPARE	6
7	PROCEDURE	1620		1	20	A	20	1		1000	STAFF	8
9	EXAM BEDS	1200		1	20	B	20	1		1200	REFRIGERATOR	10
11	EXAM	1800		1	20	C	20	1		1440	STAFF	12
13	EXAM	1980		1	20	A	20	1		1400	RESTROOM, CORRIDOR	14
15	EXAM	400		1	20	B	20	1		1800	PROCEDURE	16
17	REFRIGERATOR	1200		1	20	C	20	1		1800	PROCEDURE	18
19	SKINM SURG. CONS., FIT	1000		1	20	A	20	1		1000	EXAM LIGHT	20
21	EXAM (4)	1150		1	20	B	20	1		1200	REFRIGERATOR	22
23	SOIL, PROC., EXAM (2)	1425		1	20	C	20	1		1200	MICROWAVE	24
25	SCOPE, STAFF, EXAM (2)	1250		1	20	A	20	1		500	DOOR OPERATOR	26
27	PROC., CUST. STOR.	875		1	20	B					SPACE ONLY	28
29	SPARE (EXISTING CIRCUIT)			1	20	C					SPACE ONLY	30
31	SPARE (EXISTING CIRCUIT)			1	20	A					SPACE ONLY	32
33	SPARE (EXISTING CIRCUIT)			1	20	B					SPACE ONLY	34
35	SPARE (EXISTING CIRCUIT)			1	20	C					SPACE ONLY	36
37	CORR., AUDIO	825		1	20	A					SPACE ONLY	38
39	CORR.	400		1	20	B					SPACE ONLY	40
41	WAIT, RECEPT.	900		1	20	C					SPACE ONLY	42



Department of  
Veterans Affairs